


NOTES:

WATER MAIN CROSSING EXISTING FORCE MAIN SHALL BE LAID TO PROVIDE A VERTICAL DISTANCE OF 18 INCHES BETWEEN THE INVERT OF THE UPPER PIPE AND THE CROWN OF THE LOWER PIPE. A MINIMUM SEPARATION OF 10 FEET BETWEEN ANY TWO JOINTS. ALL CROSSINGS SHALL BE ARRANGED SO THAT THE SEWER PIPE JOINTS AND THE WATER MAIN PIPE JOINTS ARE EQUAL DISTANCE FROM THE POINT OF CROSSING (PIPES CENTERED ON THE CROSSING). IN ALL CASES AN 18" VERTICAL SEPERATION SHALL BE REQUIRED.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

UTILITY CROSSING

DATE: OCTOBER 2021
 FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

16