


SECTION A-A

NOTES

1. CASING INSULATORS SHALL BE MADE WITH SPECIAL RUNNER HEIGHTS SO AS NOT TO INTERFERE WITH PIPE JOINTS.
2. ALL CARRIER PIPES MUST HAVE MECHANICALLY RESTRAINED JOINTS.
3. INSULATOR SPACING SHALL BE AS REQUIRED BY THE MANUFACTURER, HOWEVER, NO LESS THAN FOUR (4) CASING INSULATORS SHALL BE INSTALLED PER LENGTH OF PIPE.
4. CASING LENGTH SHALL EXTEND A MINIMUM OF 8 FEET BEYOND THE EDGE OF PAVEMENT OR CURBING.
5. LOCATOR WIRE MUST BE INSTALLED THROUGH CASING.

JACK & BORE DETAIL



STANDARD UTILITY DETAILS
 City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

JACK & BORE DETAIL

DATE: OCTOBER 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER
18