


**NOTES:**

1. BLUE 10 GAUGE THHN WIRE SHALL BE ATTACHED TO THE SERVICE LINE.
2. WHERE SERVICES UNDER PAVEMENT ARE REQUIRED, THE POLYETHYLENE TUBING SHALL BE INSTALLED WITHIN SCHEDULE 40 PVC CASING PIPE.
3. ALL METER SIZES SHALL REQUIRE A LOCKABLE CURB STOP.
4. MINIMUM COVER IN UNPAVED AREAS IS 18", IN PAVED AREAS OR PLANNED ROADWAYS OR SWALES MIN. COVER SHALL BE 36".
5. REVERSE TAPS ARE STRICTLY PROHIBITED.



**STANDARD UTILITY DETAILS**  
 City of Stuart  
 Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

**SINGLE WATER SERVICE CONNECTION**

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

**23**