


NOTES:

1. BLUE 10 GAUGE THHN WIRE SHALL BE ATTACHED TO THE SERVICE LINE.
2. WHERE SERVICES UNDER PAVEMENT ARE REQUIRED, THE POLYETHYLENE TUBING SHALL BE INSTALLED WITHIN SCHEDULE 40 PVC CASING PIPE.
3. 3/4" & 1" METER SIZES SHALL REQUIRE A LOCKABLE CURB STOP.
4. MINIMUM COVER IN UNPAVED AREAS IS 18", IN PAVED AREAS OR PLANNED ROADWAYS OR SWALES MIN. COVER SHALL BE 36".
5. REVERSE TAPS ARE STRICTLY PROHIBITED.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994

DOUBLE WATER SERVICE CONNECTION

DATE:	OCTOBER 2021	SHEET NUMBER
FILE NAME:	2021 COS Std Details.dwg	24