


TYPICAL POTABLE / RECLAIMED WATER METER WITH
BACKFLOW PREVENTION ASSEMBLY
5/8" - 3/4"
(COMMERCIAL / IRRIGATION)

NOTES:

1. RECLAIMED WATER BACKFLOW PREVENTION ASSEMBLY MUST BE PAINTED PURPLE PANTONE 522.
2. METER TO BE SUPPLIED BY THE CITY OF STUART.
3. BACKFLOW PREVENTION ASSEMBLY MUST BE COVERED BY LANDSCAPE.
4. NO TAPS OR CONNECTION ALLOWED BETWEEN THE METER AND BACKFLOW PREVENTION DEVICE.



STANDARD UTILITY DETAILS
 City of Stuart
 Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

BACKFLOW PREVENTION ASSEMBLY

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

30