

PUMP DATA:

MANUFACTURER, _____

MODEL No. _____ IMP. No. _____ MOTOR, _____ HP,

_____ RPM, _____ VOLTS, _____ PHASE, 60 HERTZ

OPERATING CONDITIONS:


_____ GPM AT _____ TDH. _____ % EFFICIENCY

WET WELL:

SIZED FOR MINIMUM PUMP CYCLE TIME OF 10 MINUTES AND A MAXIMUM OF 6 PUMP STARTS PER HOUR. WORKING DEPTH _____ FT. WORKING VOLUME _____ GALS.

ELECTRICAL:

FEEDERS AND CONDUIT _____ MAIN SWITCH _____ POLES _____ AMPS



STANDARD UTILITY DETAILS
City of Stuart
Utilities & Engineering Department

121 S.W. Flagler Avenue, Stuart, Florida 34994

LIFT STATION DATA

DATE: OCTOBER 2021

FILE NAME: 2021 COS Std Details.dwg

SHEET NUMBER

54