


**NOTES:**

1. ELECTRIC METER AND PRIMARY DISCONNECT MOUNTED ON BACK SIDE OF PANEL.
2. EMERGENCY GENERATOR RECEPTACLES: PYLE NATIONAL JRE 4100 (100 amp), 2044FR (200 amp).
3. ALL POWER AND CONTROLS LINES SHALL BE CONTINUOUS ( NO SPLICES ).
4. POWER SUPPLY MECHANICALLY INTERLOCKED.
5. GROUND FAULT INTERRUPTER ON CONVENIENCE RECEPTACLE.
6. CONTROL PANEL SHALL BE UL LISTED AS A UNIT.
7. TELEMTRY CONDUIT SHALL BE INSTALLED BY THE CONTRACTOR WITH SWEEP 90° BEND.
8. ALL HARDWARE, NUTS & BOLTS, AND APPURTENANCES ABOVE GROUND SHALL BE 316 STAINLESS STEEL.
9. TCU FOR DATA FLOW MOUNTED INSIDE PANEL.



**STANDARD UTILITY DETAILS**  
 City of Stuart  
 Utilities & Engineering Department  
 121 S.W. Flagler Avenue, Stuart, Florida 34994

**LIFT STATION CONTROL PANEL**

DATE:	OCTOBER 2021	SHEET NUMBER
FILE NAME:	2021 COS Std Details.dwg	<b>57</b>