


NOTES:

1. ALL INVERT CHANNELS ARE TO BE CONSTRUCTED FOR SMOOTH FLOW WITHOUT OBSTRUCTION.
2. PROPERLY SHAPED SPILLWAYS SHALL BE CONSTRUCTED BETWEEN PIPES WITH DIFFERENT INVERT ELEVATIONS TO PROVIDE FOR SMOOTH FLOWS.
3. BRICK AND CONCRETE PERMITTED AS FLOW CHANNEL BUILDUP.
4. SIDEWALLS OF FLOW CHANNEL SHALL BE AT LEAST HALF OF PIPE HEIGHT AT ALL POINTS.

INVERT FLOW CHANNEL DETAIL



STANDARD UTILITY DETAILS
City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

**INVERT FLOW
 CHANNEL DETAIL**

DATE: OCTOBER 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER
40