


**NOTE:**  
 SERVICE LATERALS SHALL TERMINATE AT  $\mathbb{R}$  AT A DEPTH OF (3) FEET, PLUGGED WATERTIGHT AND MARKED WITH 2"x2" TREATED STAKE AND ELECTRONIC MARKER

**SERVICE CONNECTION**  
**(LATERAL)**



**STANDARD UTILITY DETAILS**  
 City of Stuart Public Works Department  
 121 S.W. Flagler Avenue, Stuart, Florida 34994  
 (772) 288-5300

**SERVICE CONNECTION**  
**(LATERAL)**

DATE: OCTOBER 2016  
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER  
**41**