

1. LOW PRESSURE PUMPING UNITS SHALL BE LOCATED SO THAT SURFACE WATER RUN OFF SHALL NOT INTERFERE WITH ELECTRICAL COMPONENTS.
2. MANUFACTURER SHALL SUPPLY AND ATTACH ELECTRICAL CONTROL PANEL SCHEMATIC TO INSIDE FACE OF CONTROL PANEL DOOR.
3. LIFT STATION AND CONTROL PANEL SHALL BE LOCATED SO THAT BOTH ARE ACCESSIBLE FOR MAINTENANCE.
4. WHERE FEASIBLE, HOMEOWNER SHALL PROVIDE WATER HOSE BIB. HOSE FOR MAINTENANCE OPERATIONS W/ BACKFLOW DEVICE.
5. AIR RELEASE VALVE AND/OR VACUUM RELIEF VALVES SHALL BE PROVIDED ON ALL LOW PRESSURE FORCE MAIN INSTALLATION IMMEDIATELY UPSTREAM OF DISCHARGE POINT TO REGIONAL GRAVITY OR FORCE MAIN SYSTEMS.
6. FORCE MAIN MARKING TAPE OR MAGNETIC LOCATING DEVICES WILL BE INSTALLED OVER FORCE MAIN, VALVES, AND SERVICES, 18" MAX. BURIED DEPTH.
7. FORCE MAIN SHALL HAVE TRACER WIRE—#10 AWG, SOLID COPPER TYPW THHN W/ GREEN INSULATION SECURED TO PIPE.

# GENERAL NOTES:



**STANDARD UTILITY DETAILS**  
 City of Stuart Public Works Department  
 121 S.W. Flagler Avenue, Stuart, Florida 34994  
 (772) 288-5300

## GENERAL NOTES

DATE: OCTOBER 2016  
 FILE NAME: 2016 COS LP Details.dwg

SHEET NUMBER  
**LP-1**