



NOTES:

1. ALL PIPING SHALL BE MINIMUM OF 6"
2. PIPING SHALL BE INSTALLED USING A CONCRETE MANHOLE ADAPTER.
3. SANITARY 'T' SHALL BE INSTALLED 4" INSIDE MANHOLE WALLS.
4. SECTIONS SHALL BE JOINED AND SEALED WITH MINIMUM 1 3/4" "RAM-NEK" SEALER OR EQUIVALENT TO FORM A WATER TIGHT SEAL.
5. WALLS & BOTTOM SLABS MINIMUM 4" THICK REINFORCED CONCRETE.

OPTIONS:

1. TANKS INSIDE BUILDING AS IS.
2. OUTSIDE BUILDING
 - A. ABOVE SURFACE WATER
 - B. POST PROTECTION FROM TRAFFIC

LINT TRAP



STANDARD UTILITY DETAILS
 City of Stuart Public Works Department
 121 S.W. Flagler Avenue, Stuart, Florida 34994
 (772) 288-5300

LINT TRAP

DATE: OCTOBER, 2016
 FILE NAME: 2016 COS Std Details.dwg

SHEET NUMBER

46