



City of Stuart Fire Rescue

Office of Fire Prevention

800 SE Martin Luther King, Jr. Boulevard

Stuart, FL 34994-2408

David Dyal, Fire Chief



fireprevention@ci.stuart.fl.us

www.cityofstuart.us

Telephone (772) 288-5360

Facsimile (772) 288-5371

LIFESAFETY INSPECTION GUIDE

The following information is provided to assist and to expedite the inspection process. While not intended to be all-inclusive, this guide addresses the most common violations found during inspections. The inspector will contact you once the application has been process and the inspection request is forwarded to him/her. Please contact 772-288-5360, ext 2 if you have any questions.

ALL BUSINESSES

Business Information Name

Phone Number

Address

Contact person

Building Numbers 6-inch on front, 4-inch on rear

Contrasting with background color

Electrical Panel(s) at least 36 inches of clearance, clearly labeled, with no voids

Wiring in conduit and connection in junction boxes

Cover plates on outlets, GFCI outlets where shock hazard exists

Exits Clear of obstructions

Doors unlocked to occupants during business hours

Number of exits varies by occupancy type- inspector will verify compliance

Fire Extinguishers At least on 5-lb ABC extinguisher every 3,000 sq ft with maximum 75-ft travel distance

Additional extinguishers may be required for higher hazard occupancies

Must be mounted no more, at the top of the extinguisher, than 5 fl from the floor

Must be visible and readily accessible

WHERE REQUIRED BY CODE

Fire Alarm System Current inspection tag on Fire Alarm Panel

Alarm log with inspection records and system diagram

Fire Sprinkler System Fire department connection clear of obstructions and inlets capped

Backflow preventer inspected annually

Valves monitored by fire alarm

Current inspection tag on main riser

Spare sprinkler heads and wrench on site

18 inches of clearance around sprinkler heads

Hood System Current inspection tag

Grease filters and ductwork clean

Fans operational

Tenant Separation Firewalls with compliant protection of penetrations

FEES

The fee schedule for inspections, as approved by the City Commission under Resolution 77-2009 is as follows:

0- 2500 square feet	\$50
2501 - 5000 square feet	\$100
5001 - 20,000 square feet	\$200
20,001-100,000 square feet	\$300
Over 100,000 square feet	\$500